



## Memo

To: Board of Education  
Dr. Ben Collins, Superintendent

From: Dr. Adam Parisi, Chief School Business Official  
Mr. Noel Mendoza, Director of Facility Management

Date: December 12, 2023

Re: Approval of Summer 2024 Construction Projects

After the November 16, 2023, Board Meeting, the District conducted several environmental tests to determine the level of mercury in the gymnasium floors. The complete results are included in the Board packet.

The OSHA permissible exposure limit for mercury vapor is 0.1 mg/m<sup>3</sup> or 100 µg/m<sup>3</sup>. The summary of the results demonstrates levels significantly lower than that:

22-Nov-23,07:11:18, 0.00,µg/m<sup>3</sup>,,CARPENTER ELEM  
22-Nov-23,07:12:04, 0.06,µg/m<sup>3</sup>,,CARPENTER ELEM  
22-Nov-23,07:31:05, 0.04,µg/m<sup>3</sup>,,ROOSEVELT ELEM  
22-Nov-23,07:32:01, 0.03,µg/m<sup>3</sup>,,ROOSEVELT ELEM  
22-Nov-23,07:35:50, 0.00,µg/m<sup>3</sup>,,ROOSEVELT ELEM  
22-Nov-23,07:36:39, 0.00,µg/m<sup>3</sup>,,ROOSEVELT ELEM  
22-Nov-23,07:48:44, 0.01,µg/m<sup>3</sup>,,WASHINGTON ELEM  
22-Nov-23,07:49:27, 0.06,µg/m<sup>3</sup>,,WASHINGTON ELEM  
22-Nov-23,08:06:40, 0.31,µg/m<sup>3</sup>,,FRANKLIN ELEM  
22-Nov-23,08:07:35, 0.00,µg/m<sup>3</sup>,,FRANKLIN ELEM  
22-Nov-23,08:21:25, 0.00,µg/m<sup>3</sup>,,FIELD ELEM  
22-Nov-23,08:22:17, 0.00,µg/m<sup>3</sup>,,FIELD ELEM  
22-Nov-23,08:25:02, 0.01,µg/m<sup>3</sup>,,FIELD ELEM  
22-Nov-23,08:26:04, 0.04,µg/m<sup>3</sup>,,FIELD ELEM

Therefore, the Administration is recommending the option of an overpoured floor without abating the mercury.

| <b>Bid Package #2 - Flooring</b> |                        |                          |                       |
|----------------------------------|------------------------|--------------------------|-----------------------|
| <u>Contractor</u>                | <u>Base Bid</u>        | <u>A-Mondo Overlay</u>   | <u>A-Mondo Full</u>   |
| Prostar                          | \$372,584*             | No Bid                   | No Bid                |
| Kiefer                           | No Bid                 | \$613,010                | \$780,270             |
|                                  |                        |                          |                       |
| <u>Contractor</u>                | <u>A-Full Urethane</u> | <u>A-Tarkett Overlay</u> | <u>A-Tarkett Full</u> |
| Prostar                          | \$266,916              | \$212,416                | \$310,916             |
| Kiefer                           | No Bid                 | No Bid                   | No Bid                |
|                                  |                        |                          |                       |

ACTION ITEM 23-12-01

I move that the Board of Education of Community Consolidated School District 64, Park Ridge – Niles, Illinois, approve the awarding of the flooring bid package #2 to Prostar in the amount of \$372,584.

The votes were cast as follows:

Moved by \_\_\_\_\_ Seconded by \_\_\_\_\_

AYES:

NAYS:

PRESENT:

ABSENT: