



1429 Centre Circle Drive
Downers Grove, IL 60515
Phone: (630) 691-8271
Fax: (630) 691-1819
E-Mail: uasinc@uas1.com

UNITED ANALYTICAL SERVICES, INC.

November 21, 2017

Park Ridge-Niles School District #64
164 S. Prospect Avenue
Park Ridge, Illinois 60068

UAS Project 1798560-01

Attn: Mr. Ron DeGeorge, Director of Building and Grounds
**Re: Summary of Findings - Lead in Drinking Water Sampling & Lab Analysis
Park Ridge - Niles School District #64
Lincoln School -
200 S. Lincoln Avenue, Park Ridge, Illinois 60068
November 1, 2017**

Dear Mr. DeGeorge:

United Analytical Services, Inc. (UAS) prepared this executive summary of findings for the drinking water sampling performed at Park Ridge-Niles School District #64's Lincoln School located at 200 S. Lincoln Avenue in Park Ridge, Illinois on November 1, 2017. The current testing involved collecting drinking water samples from ALL thirty (30) of the drinking water sources/locations throughout the school facility that are accessible to the Students, Faculty and Staff, with subsequent laboratory analysis for the presence of Lead. Including 1st draw and 2nd draw samples at each of the drinking water sources, a total of sixty (60) water samples were collected during this current assessment.

It should be noted that at the request of Park Ridge-Niles School District #64, the current sampling included the IDPH required drinking water sources within facility, as well as a number of non-required drinking water and/or potable water sources within the school building.

The laboratory results reveal that the reported concentrations for sixty (60) of the sixty (60) drinking water samples resulted in concentrations below the IDPH public notification/communication target level of 5 µg Lead/L. Zero (0) of the sixty (60) samples revealed a drinking water concentration above the IDPH public notification/communication target level of 5 µg Lead/L.

SAMPLING REQUIREMENTS AND METHODOLOGY -

The current sampling and reporting followed the Illinois Public Act 99-0922 requirements. Following the IDPH requirements and reporting, it should be noted that UAS performed and provided the services noted below, including, but not limited to, the following:

1. The current testing and analysis was limited only to those thirty (30) locations/sources noted.
2. UAS provided fixture/source identifiers for each of the sources/locations identified with alphanumeric identifiers for each fixture and sample.
3. UAS utilized sampling media (250 mL sample bottles) obtained from a State of Illinois Environmental Protection Agency (IEPA) accredited laboratory, labeled all sampling bottles with the alphanumeric identifiers and prepared a Chain of Custody form for samples.
4. The IEPA accredited laboratory that UAS utilized to perform the laboratory analysis for this project was Pace Analytical Services, LLC (Pace) of Minneapolis, MN. Pace is recognized by the IEPA as NELAP-Recognized Environmental Laboratory for Lead in Drinking Water. A copy of the SLI accreditation for the approved method is attached. UAS confirmed with SLI, that the IDPH required minimum reporting limit (MRL) and significant digits requested by IDPH could be utilized and documented. The MRL identified by IDPH, and utilized for this assessment was 2.00 µg Lead/L, or lower.
5. Following confirmation from Park Ridge-Niles School District #64 (S.D. #64) that each of the target drinking water sources/systems had been allowed a mandated stagnation period of eight (8) to eighteen (18) hours, UAS collected the required 1st Draw and 2nd Draw (30 second flush) drinking water samples from each drinking water fixture/source identified by S.D. #64. S.D. #64 reported that the last use of any of the sources/fixtures in the school was 8:00 p.m. on October 31, 2017, following a day of typical school occupancy and usage within the facility. The sample collection by UAS began at 4:55 a.m. on November 1, 2017 and was completed prior to any water use within the building.
6. UAS completed and compiled Chain of Custody forms for the school building samples.
7. UAS submitted the samples to Pace following strict Chain of Custody protocols.
8. UAS compiled this final summary report with results for this school using IDPH's guidance for reporting, data and information spreadsheet to ensure consistency and reliability.
10. All sampling, documentation and reporting was performed under the direct supervision of an Illinois Department of Public Health (IDPH) licensed Lead Inspector/Risk Assessor.

IDPH REPORTING & PUBLIC NOTIFICATION -

As required, IDPH Reporting and Public Notification requirements shall be the responsibility of Park Ridge-Niles School District #64. Please note the following: Illinois Public Act 099-0922: Within seven (7) days of receipt of these test results, the district/school must email all test results to IDPH. If any of the samples taken in the school exceed 5 parts per billion (µg/L), the school district or chief school administrator, or the designee of the school district or chief school administrator, shall promptly provide an individual notification of the sampling results, via written or electronic communication, to the parents or legal guardians of all enrolled students and include the following information: the corresponding sampling location within the school building and the United States Environmental Protection Agency's website for information about lead in drinking water. If any of the samples taken at the school are at or below 5 parts per billion (µg/L), notification may be made by posting on the schools website.

TEST RESULTS / SUMMARY OF FINDINGS-

The test results are noted in the attached Spreadsheet and Analytical Laboratory Reports. The current testing and analysis was limited only to those thirty (30) locations/sources noted. Review of the current testing laboratory data reveals the following:

The results from twenty-eight (28) of the thirty (30) locations/sources revealed concentrations below both the IDPH mitigation strategies lower limit of 2 ppb, and below the IDPH public notification/communication target level of 5 µg Lead/L.

Two (2) of the thirty (30) locations/sources reported concentrations at/above the IDPH mitigation strategies lower limit of 2 ppb, but below the IDPH public notification/communication target level of 5 µg Lead/L.

Zero (0) of the thirty (30) locations/sources revealed a drinking water concentration above the IDPH public notification/communication target level of 5 µg Lead/L.

Pursuant to Public Act 99-0922, the Illinois Plumbing Licensing Law (225 ILCS 320/35.5), the IDPH is required to provide guidance to schools concerning mitigation of hazards discovered by testing for lead in water. While Section 35.5 does not require mitigation, IDPH is requiring the mitigation strategies and requirements contained in their Guidance Document for Mitigating Lead in Schools (copy attached) to be followed for all plumbing fixtures identified with any level of lead. IDPH further notes that mitigation strategies should continue until subsequent testing indicates no lead is present in water.

RECOMMENDATIONS -

At this time, UAS recommends the following:

1. Along with their standard water programs, Park Ridge-Niles School District #64 should follow the IDPH reporting requirements, as well as the mitigation strategies and requirements contained in their Guidance Document for Mitigating Lead in Schools (copy attached) for the sources, locations and fixtures that were identified with lead greater than 2 parts per billion (µg/L). IDPH further notes that mitigation strategies should continue until subsequent testing indicates no lead (<2.00 ppb) is present in water. While not applicable at this school, it should be noted that any source, location and fixture that is identified with lead of 5 parts per billion (µg/L) or greater should be taken “off-line”, either permanently, or until such time that mitigation and subsequent testing demonstrate that lead levels are within acceptable IDPH limits.
2. Park Ridge-Niles School District #64 should provide this report and results to IDPH in accordance with Illinois Public Act 099-0922.
3. Pursuant to Public Act 99-0922, the Illinois Plumbing Licensing Law (225 ILCS 320/35.5), the IDPH is required to provide guidance to schools concerning mitigation of hazards discovered by testing for lead in water. While Section 35.5 does not require mitigation, IDPH is requiring the mitigation strategies and requirements contained in their Guidance Document for Mitigating

Mr. Ron DeGeorge, Director of Building and Grounds
Summary of Findings - Lead in Drinking Water Sampling & Lab Analysis
Park Ridge - Niles School District #64
Lincoln School -
200 S. Lincoln Avenue, Park Ridge, Illinois 60068

November 21, 2017

Page – 4 –

Lead in Schools (copy attached) to be followed for all plumbing fixtures identified with any level of lead. IDPH further notes that mitigation strategies should continue until subsequent testing indicates no lead (i.e. <2.00 ppb) is present in water.

Thank you for the continued opportunity to be of service to Park Ridge-Niles School District #64. If you have any questions regarding this information, please do not hesitate to contact our office.

Sincerely,
UNITED ANALYTICAL SERVICES, INC.

Thad Daniels
Director of Field Services
Lead Risk Assessor (IL 001047)

attachments: IDPH Spreadsheet Summary of Lead in Drinking Water
11/20/17 Laboratory Report & COCs
IDPH Mitigation Strategies
UAS' Inspector/Sample Collector License & Accreditation
Pace Laboratory Accreditation

cc: Kevin E. Aikman, Ph.D., CIH, FAIHA (UAS)

S:\VTD\HRReports\SD64.Lincoln.1798560-01.Report

14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-22b	Gymnasium East DWC	WF - Water Cooler	10/31/2017	8:00 PM	Flush	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-23a	Gymnasium DWC West	WF - Water Cooler	10/31/2017	8:00 PM	First Draw	250	Pace Labs	EPA 200.8	2.10	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-23b	Gymnasium DWC West	WF - Water Cooler	10/31/2017	8:00 PM	Flush	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-24a	Cafeteria DWC East	WF - Water Cooler	10/31/2017	8:00 PM	First Draw	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-24b	Cafeteria DWC East	WF - Water Cooler	10/31/2017	8:00 PM	Flush	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-25a	Cafeteria West DWC	WF - Water Cooler	10/31/2017	8:00 PM	First Draw	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-25b	Cafeteria West DWC	WF - Water Cooler	10/31/2017	8:00 PM	Flush	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-26a	Kitchen Food Prep Sink East	KS - Kitchen Sink	10/31/2017	8:00 PM	First Draw	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-26b	Kitchen Food Prep Sink East	KS - Kitchen Sink	10/31/2017	8:00 PM	Flush	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-27a	Kitchen Food Prep Sink West	KS - Kitchen Sink	10/31/2017	8:00 PM	First Draw	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-27b	Kitchen Food Prep Sink West	KS - Kitchen Sink	10/31/2017	8:00 PM	Flush	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-28a	Fitness Room DWC	WF - Water Cooler	10/31/2017	8:00 PM	First Draw	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-28b	Fitness Room DWC	WF - Water Cooler	10/31/2017	8:00 PM	Flush	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-29a	Nurse's Office Sink	S - Sink	10/31/2017	8:00 PM	First Draw	250	Pace Labs	EPA 200.8	3.40	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-29b	Nurse's Office Sink	S - Sink	10/31/2017	8:00 PM	Flush	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-30a	Auditorium Hallway DWC	WF - Water Cooler	10/31/2017	8:00 PM	First Draw	250	Pace Labs	EPA 200.8	<2.00	0.10	
14-016-0640-1007	LS	Lincoln School	11/1/17	4:55 AM	IL 001047	LS-30b	Auditorium Hallway DWC	WF - Water Cooler	10/31/2017	8:00 PM	Flush	250	Pace Labs	EPA 200.8	<2.00	0.10	

R = Right

L = Left

ND = None Detected

BFS = Bottle Filling Station